



CERTIFICATE

№ EMC- 14- 000- (2emc-14-904)- 060E

"CTEC" Ltd. certifies that

Product

LUMINAIRE

type: **BELLA T8**, cat. № **9BE236**
230 V AC; 50 Hz; 2 x 36 W; Class I; IP 65

Manufacturer

ELMARK INDUSTRIES SC, Bulgaria

2, Dobrudja Blvd. Dobrich, Bulgaria
tel.: + 359 58 500 055; fax: +359 58 500 060
e-mail: elmarkfactory@elmark.bg

Complies with the EN 55015:2006+A1:2007+A2:2009 Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
EN 61000-3-2:2006+A1:2009+A2:2009 Electromagnetic compatibility Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)
EN 61000-3-3:2008 Electromagnetic compatibility (EMC) – Part 3-3: Limits Limitation of voltage changes, voltage fluctuations and flicker in public low- voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection
EN 61547:2009 Equipment for general lighting purposes EMC immunity requirements
EN 61000-4-2:2009 *Electromagnetic compatibility Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test*
EN 61000-4-4:2004+A1:2010 *Electromagnetic compatibility Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test*
EN 61000-4-5:2006 *Electromagnetic compatibility (EMC) Part 4-5: Testing and measurement techniques - Surge immunity test*
EN 61000-4-8:2010 *Electromagnetic compatibility (EMC) Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test*
EN 61000-4-11:2004 *Electromagnetic compatibility (EMC) Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

Certificate has been issued on the base of

Test reports:
№ 2emc-e-14-904/20.06.2014
№ 2emc-i -14-904/20.06.2014

Date of issue: 2014-09-30
Stara Zagora

Manager CTEC Ltd.
/dipl. eng. Blagovesta Shineva/

